MNA LABORATUVARLARI



TECHNICAL EVALUATION REPORT

Report No

: 65-20-01

Report Date

: 28.10.2020

Application No

: 65-20-01

1. COMPANY INFORMATION:

LindenCare GmbH

Pempelforter Str. 50, 40211 Düsseldorf, Germany

Tel: +90 545 903 26 06

Fax: -

E-mail: a.cansu@kloepfel-consulting.com

2. PPE INFORMATION:

Disposable and non-sterile half mask made of particulate protection filter material.

3. PPE TYPE IDENTIFICATION

EN 149 +A1 Respiratory protective devices - Filtering half masks to protect against particles - Requirements, testing, marking

4. PPE PICTURES



LINDENPARTNER LP2

5. PPE DIMENSIONS:

LP2 model has been found to be produced using standard sizes.

MNA LABORATUVARLARI



TECHNICAL EVALUATION REPORT

6. PPE PRODUCT MATERIAL INFORMATION:

The mask is made of elastic ear strap and non woven fabric on the outer and inner layers and filter material on the middle layer.

7. ESSENTIAL HEALTH AND SAFETY REQUIREMENTS

- A visual inspection was made according to EN 149 + A1 for ergonomics.
- Protection levels and degrees are defined by the manufacturer.
- Suitable construction materials were determined by visual inspection according to EN 149 + A1.
- Respiratory protective dimensions are evaluated according to EN 149 + A1.
- Conditioning EN 149 + A1 part 8.3, Penetration EN 149 + A1 part 8.11 (EN 13274-7), Application performance EN 149 + A1 part 8.4, Inward leakage EN 149 + A1 part 8.5, Flammability EN 149 + A1 part 8.6, The carbon dioxide content of the inhaled air EN 149 + A1 part 8.7, Inhalation resistance EN 149 + A1 part 8.9, Exhalation valve connection resistance EN 149 + A1 part 8.8, Exhalation resistance EN 149 + A1 part 8.9 has been tested and evaluated.

8. ANALYSIS AND EVALUATIONS:

EN 149 +A1

TESTS	PARAMETER	PERFORMANCE LEVELS			RESULTS	PERFORMAN CE LEVELS	EVALUATION
		FFP1	FFP2	FFP3			
Visual inspection	Shall also the markin supplied by the manuf			rmation	Appropriate	-	PASS
	At least 46 out of the 50 individual exercise result	<25	<11	<5	6,8	FFP2	PASS
Total inward leakage	At least 8 out of the 10 individual wearer	<22	<8	<2	6,4	FFP2	PASS
Flammibility	Mask shall not burn burn for more than 5 s		to conti	inue to	Flame not seen	-	PASS
Carbondioxide content of the inhalation air	Shall not exceed an av	erage of	% 1		0,57	-	PASS
Penetration of filter material	Sodium chloride, 95 L/min %, max	% 20	% 6	%1	3,5	FFP2	PASS



MNA LABORATUVARLARI

TECHNICAL EVALUATION REPORT

	Paraffin oil, 95 L/min %, max	% 20	% 6	%1	3,3	FFP2	PASS
Compatibility with skin	Materials shall not be known to be likely to cause irritation or any other adverse effect to health				Appropriate	-	PASS
Head harness	It can be donned and	deasily		Appropriate	-	PASS	
Breathing Resistance	İnhalation 30L/min	0,6 mbar	0,7 mbar	1 mbar	0,6	FFP2	PASS
	İnhalation 95L/min	2,1 mbar	2,4 mbar	3 mbar	1,7	FFP2	PASS
	Exhalation 160L/min	3 mbar	3 mbar	3 mbar	2,5	FFP2	PASS

9. DECISION PROPOSAL

Analysis and examinations LP2 model coded personal respiratory protection; Respiratory Protective Devices EN 149 + A1 - Filtered Half Masks for Protection Against Particles - Properties, Experiments and Marking standards are evaluated. It is recommended to be certified at the performance levels specified as a result of technical evaluations.

10. ATTACHMENTS

- Basic Health Safety Requirements
- Risk Assessment
- **Test Reports**
- User Instruction

CONTROLLER

: VOLKAN AKIN

SING

DATE